## **Manufacturer Declaration**

## Siemens AG Infrastructure & Cities Sector Building Technologies Division

Product:

EN EN

Burner Control LFL...

Approval:

EN 298

Application:

Burner Control for gas firing systems

Burner controls LFL... are dedicated for use in safety relevant systems up to SIL3. The suitability within a subsystem has to be evaluated in connection with various linked components.

Parameter as per EN 13849:

MTTF<sub>D</sub> = 150 years PFH<sub>D</sub> =  $\lambda_{D}$  = 7.61\*10-7

Rastatt, February 06, 2012

i.V. Thinform

i. V. Thomas Gnoss PM

1.V. M.

i. V. Martin Sink QAS



www.siemens.com