

Certificate of Compliance

Certificate: 1602938 (LR 106568)

Project: 1956647

Issued to:

Siemens Building Technologies HVAC Products GmbH Werk Rastatt **Berliner Ring 23** Rastatt, 76437 Germany Attention: Ms. Ingrid Blank

Master Contract: 162938

Date Issued:

2007/11/09

The products listed below are eligible to bear the CSA Mark shown



Issued by:

Joseph Kwong, P. Eng.

Authorized by: Akbar Lalani, Product Group Manager

fer an

PRODUCTS CLASS 3221 02 - VALVES - Actuators

Motorized electric actuator, Model SQN7; f/b 0 or 1; f/b .2, .4, or .6; f/b 03 R1; f/b 0. 3, 6, or 9; rated 120V ac. 6VA, 50/60Hz; maximum 60°C ambient; duty cycle at 50% motor on time; maximum 30 s on time: 100.000 cycles.

Notes: 1. The subject devices are Certified as component application.

2. The devices are intended for factory wiring only.

DQD 507 Rev. 2004-06-30

		Supplement to Certificate of Compliance
Certificate	1602938	Master Contract: 162938
	The product	ts listed, including the latest revision described below, are eligible to be marked in accordance with the referenced Certificate.
		Product Certification History
Project	Date	Description
1956647 1602938	2007/11/09 2004/11/26	Report corrections. Original Certification
	x	